


A sample of the following product has been tested and is stated by Nemko to be in conformity with the below cited requirements

Applicant	FAAC S.p.A. Via Benini, 1 I - 40069 Zola Pedrosa (BO)
Manufacturer	FAAC S.p.A. Via Benini, 1 I - 40069 Zola Pedrosa (BO)
Product	Free standing automated system for sliding pedestrian door
Model/type	A100 COMPACT 2
Data	230 V – 50 Hz – 100 W
Additional information	Trademark 
The tested equipment was found complying with the requirements	Durability test - 2.000.000 cycles Customer request based on DIN 18650-1:2005-12, sub-clause 7.1.2
Results of performed tests are shown in the test report(s)	Nemko SpA – 128092TRFSAF issued 2009-05-14
Statement reference	128092
Variants	None

This Statement of Conformity refers to the verified type(s), does not involve production surveillance and does not allow the use of the Nemko mark on the product.

Date of issue 2009-05-14

Statement of Conformity Revision: 0



signature

Alberto Reati

Certification Department